

DIRECTIONS: Shake can well. Hold can 2-4 feet below smoke detector and spray at unit for 2-3 seconds. If alarm does not sound within 5 seconds, immediately repeat the process. Some units have built-in delays to reduce false alarms. If alarm still fails to sound, check unit for malfunction or dead batteries.

CAUTION: Do not overspray. Overspray may reduce sensitivity until product fully evaporates. For detectors connected to sprinklers, Halon systems or a central monitoring system, be sure system is in the test mode before using SMOKE TEST. Not for use on carbon monoxide detectors.



69G6 Smoke-Automatic
Fire Detector Accessory

©1995 CRC Industries, Inc.
Warminster, PA 18974
800-521-3168 (Tech. Info.)
800-272-4620 (Cust. Serv.)
Made in U.S.A. CRC#418 95A

Part No. 14160 DOT 2P

Patent Number 5,076,966



CRC

smoke test™

Smoke Detector Tester

Easy
Convenient
Safe

NET WT.
1 OZ.
(29 g)

See back panel for
additional warnings.

DANGER: EXTREMELY FLAMMABLE. CONTENTS UNDER PRESSURE.

WARNING: Contains Ethanol 64-17-5, 1,2,3 Propanetriol 56-81-5, Propane 74-98-6 and Isobutane 75-28-5. Do not puncture, incinerate, or store can above 120°F. Exposure to high temperature may cause can to burst. Keep away from ignition sources. Do not place in direct sunlight or near other heat sources. Do not spray while smoking. Overexposure may cause eye irritation. Avoid eye contact. In case of eye contact, flush thoroughly with water for 15 minutes. Do not discard empty can into home garbage compactors. Deliberate misuse by inhaling contents may be harmful or fatal. If too much is breathed remove to fresh air. For severe overexposure call a physician immediately. **KEEP AWAY FROM CHILDREN**

SPECIAL USAGE WARNINGS: • Contents extremely flammable. • Do not smoke while spraying. • Extinguish all flames, pilot lights, and heaters. • Vapors will accumulate readily and may ignite. Use only with adequate ventilation; maintain ventilation during use and until vapors are gone.